

CLIENT INFORMATION

Client: Matt Gammel
Requested On: May 12, 2025
Phone: [REDACTED]
Email: [REDACTED]@gmail.com

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:
support@mytapscore.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Metals and Minerals Water Test
Matrix: Drinking Water
Testing / Report ID: RROO88
Testing Facility: Microbac Laboratories
Facility Location: 505 E Broadway Ave
Maryville, Tennessee 37804

SAMPLE INFORMATION

Collection Date: May 21, 2025
Collected By: Matt Gammel
Received Date: May 23, 2025
Reported On: Jun 2, 2025
Sample Location: RO system
Sample Address: [REDACTED], Bossier City,
LA 71111, United States

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact support@mytapscore.com

SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD	EVALUATION
Hardness (Ca,Mg)	mg/L	44.2		
Hardness (Total)	mg/L	45.14		
Grains per gallon	Grains	2.64		
Sodium Adsorption Ratio		0.15		

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
Aluminum	mg/L	NOT DETECTED	0.0579	0.5	EPA 200.7	
Antimony	mg/L	NOT DETECTED	0.00045	0.001	EPA 200.8	
Arsenic	mg/L	NOT DETECTED	0.0005	0.001	EPA 200.8	
Barium	mg/L	0.00477	0.0001	0.001	EPA 200.8	< MCLG (2)
Beryllium	mg/L	NOT DETECTED	0.0002	0.001	EPA 200.8	
Boron	mg/L	0.0135	0.0034	0.01	EPA 200.7	
Cadmium	mg/L	NOT DETECTED	0.0001	0.001	EPA 200.8	
Calcium	mg/L	17.7	0.111	0.5	EPA 200.7	
Chromium (Total)	mg/L	NOT DETECTED	0.00032	0.001	EPA 200.8	
Cobalt	mg/L	NOT DETECTED	0.0001	0.001	EPA 200.8	
Copper	mg/L	0.00164	8.0E-5	0.001	EPA 200.8	< MCLG (1.3)
Iron	mg/L	NOT DETECTED	0.0605	0.5	EPA 200.7	

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Lead	mg/L	NOT DETECTED	0.00014	0.001	EPA 200.8	
Lithium	mg/L	NOT DETECTED	0.05	0.1	EPA 200.7	
Magnesium	mg/L	NOT DETECTED	0.0481	0.5	EPA 200.7	
Manganese	mg/L	0.0062	0.0002	0.001	EPA 200.8	
Mercury	mg/L	NOT DETECTED	7.0E-5	0.0002	EPA 200.8	
Molybdenum	mg/L	NOT DETECTED	0.00031	0.001	EPA 200.8	
Nickel	mg/L	NOT DETECTED	0.00061	0.001	EPA 200.8	
Phosphorus	mg/L	NOT DETECTED	0.0613	0.075	EPA 200.7	
Potassium	mg/L	NOT DETECTED	0.152	0.5	EPA 200.7	
Selenium	mg/L	NOT DETECTED	0.00096	0.001	EPA 200.8	
Silver	mg/L	NOT DETECTED	0.0002	0.001	EPA 200.8	
Sodium	mg/L	2.33	0.139	0.5	EPA 200.7	
Strontium	mg/L	0.0156	0.001	0.01	EPA 200.7	
Thallium	mg/L	NOT DETECTED	0.0001	0.001	EPA 200.8	
Tin	mg/L	NOT DETECTED	0.0017	0.005	EPA 200.8	
Titanium	mg/L	NOT DETECTED	0.0013	0.01	EPA 200.7	
Uranium	mg/L	NOT DETECTED	4.0E-5	0.001	EPA 200.8	
Vanadium	mg/L	NOT DETECTED	0.0004	0.001	EPA 200.8	
Zinc	mg/L	0.594	0.0031	0.01	EPA 200.7	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level Goal (MCL-G).

This is a non-enforceable public health objective developed by the U.S. EPA. MCLGs are set to zero for known carcinogens, or a lifetime no-effects level for non-cancer endpoints.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MOL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health
risks and treatment solutions.

gosimplelab.com/signin